WATER WELL REPORT

33/01-- 33 () Application No

Third Copy — Driller's Copy STATE O	F WASHINGTON	Peri	mit No	<u> </u>
(1) OWNER: Name HillCREST - LES ALLEN	Address 1242	w Highland	DA. OM	HARDER
		5W 4 3E 4 Sec 3	З т.ЭЭ N, R.	l.∈ w.m.
Bearing and distance from section or subdivision corner				
3) PROPOSED USE: Domestic [] Industrial [] Municipal				
Irrigation Test Well Other	show thickness of a	e by color, character, size o equifers and the kind and n , with at least one entry fo	iature of the mater	riai in each
(4) TYPE OF WORK: Owner's number of well (if more than one)		MATERIAL	FROM	то
New well Method: Dug □ Bored Deepened □ Cable Driven	三 いねかく	SAND	· _ O	3
Reconditioned [Rotary [Jetted	- HARD	Y CIAY	3	18
(5) DIMENSIONS: Diameter of well 8 inch	hes GRAVEL		10	24
Drilled 243 ft. Depth of completed well 243		<u>L</u>	26	40
(6) CONSTRUCTION DETAILS:	HARD	PAN	55	<i>55</i> 727
Casing installed: 8 "Diam. from O ft. to 218 Vi	SANCE	OF CLAR	133	182
Threaded "Diam from ft. to	Tion	OMZ	182	- 301
	_	100 CO	210	210
Perforations: Yes No Type of perforator used	WATE	E JANO	216	+13H
SIZE of perforations in. byin.	in. FINE	2 WATEL SAN		244
perforations from ft. to	. ft. }			
perforations from ft. to			·	
Screens: Yes X No -				
Manufacturer's Name Johnson - 6 Screen	100	+ CPIN - NEEDS	S TEST PURIF	
Diam. 8 Slot size 12 from 218 ft. to 228	ft.			
Diam 8 Slot size 19 from 228 ft. to 238	<u> ft.</u>			
Gravel packed: Yes 🗆 No 🔀 Size of gravel:		<u></u>		
Gravel placed from ft. to	<u>ft.</u>			
Surface seal: yes No D To what depth? 20+	ft.			
Did any strata contain unusable water? Yes [] N	70) ×		 	
Type of water? Depth of strata			19 81	
		DEC.		
(7) PUMP: Manufacturer's Name Type: Sub HP (0		——	- 	
	<u> </u>	1100 1100 E	3Er4tÖM	-
(8) WATER LEVELS: Land-surface elevation above mean sea level. 250	n .			
Artesian pressure lbs. per square inch Date				
Artesian water is controlled by (Cap, valve, etc.)				
(9) WELL TESTS: Drawdown is amount water level is lowered below static level	Work started	1980 Comp	oleted Oct	1987
Was a pump test made? Yes No I If yes, by whom?		LER'S STATEMENT		
Yield: gal/min with ft. drawdown after	" This well wa	s drilled under my juri	isdiction and thi	s report is
<u> </u>	true to the best	of my knowledge and	belief.	
Recovery data (time taken as zero when pump turned off) (water I measured from well top to water level)	NAME WH	OBEY DR	LILLE PS	
Time Water Level Time Water Level Time Water Le	evel	(Person, firm, or corporation	on) (Type or	print)
	Address OR	K HAMBOR	wn	
	······· () , , , , , , , , , , , , , , , , , , ,	1.1.	
Date of test Bailer test 15 gal/min with 3'ft. drawdown after	hrs. [Signed]	(Well D)	riller)	
tesian flow g.p.m. Date.		29 Date	OF	2 الم
Temperature of water	NO [] Picelise Mo	Date		,